

ADDENDUM NO. 1

Tennis & Pickleball Court Project – Village of Birchwood (TID 1)

This Addendum modifies and supplements the Request for Proposals titled “**Tennis Court Project RFP & Bid Specification Packet**”. All bidders shall acknowledge and comply with the requirements of this Addendum. All provisions of the original RFP not specifically modified herein remain in full force and effect.

1. Fence Specifications (Clarification and Addition)

The section titled “Work Specifications – Tennis Court”, which references “Fence installation per plan,” is hereby supplemented with the following minimum material requirements.

All fencing shall be commercial-grade galvanized chain-link fencing, meeting or exceeding industry standards, and shall include the following:

- Fabric: 9-gauge galvanized steel chain-link fabric with knuckle/knuckle selvage
- Line Posts: 2-inch outside diameter, Schedule 40 steel
- Terminal Posts: 3-inch outside diameter, Schedule 40 steel
- Top Rail: 1-5/8-inch outside diameter galvanized steel
- Installation: Fence installation shall conform to the project plans and applicable local and state requirements

No substitutions or deviations from these specifications shall be permitted without prior written approval from the Village.

2. Bid Scope Requirement (Entire Project)

All bids submitted in response to this RFP must be for the entire project scope as described in the RFP documents, including but not limited to tennis court removal and reconstruction, fencing, pavement, guardrail coordination, painting, and site restoration.

Partial bids, segmented bids, or bids excluding any portion of the project scope will not be accepted and will be deemed non-responsive.

3. Acknowledgment of Addendum

Bidders shall acknowledge receipt of this Addendum in their bid submission. Failure to acknowledge this Addendum may result in disqualification of the bid.